

Aspects of a generic Photovoltaic model examined under the German Grid Code for Medium Voltage




Dipl.-Ing. M.Sc. Ioannis-Thomas K. Theologitis


Dr.-Ing. Eckehard Tröster

Dr.-Ing. Thomas Ackermann

Energynautics GmbH, Germany



OUTLINE

- 
1. INTRODUCTION
 2. MODEL
 3. CONTROL ASPECTS
 4. CONCLUSIONS & RECOMMENDATIONS

Overview

The driving force:

- The increasing PV penetration to the power grid
(current status + future scenarios)

Requirements:

- Detailed Grid Codes to ensure proper operation of the power grid
- Further studies and modeling based on grid codes to end up in more concrete solutions

Objective:

- Group together some basic knowledge concerning the requirements that PV systems should fulfill to comply with the German Grid Code for MV

Approach:

- Examination and improvement of a generic photovoltaic model built by DIgSILENT




energynautics
solutions for a sustainable development


The German Grid Code

Grid Codes	Voltage Band	Fault Ride Through	Reactive Power Supply	Frequency Band	Active Power Derating
High Voltage (>110 kV)	0.8 U _N ↔ 1.16 U _N	✓	<u>Method</u> U, cosφ, Q <u>Limitations</u> Q/P _n and voltage level (3 different variants)	47.5 Hz ↔ 51.5 Hz	$\Delta(\frac{P}{P_M}) = 40\% \text{ (50.2Hz} - f)$ 50.2Hz < f < 51.5Hz
Medium Voltage (<110 kV & >10 kV)	0.8 U _N ↔ 1.15 U _N	✓	<u>Method</u> Q(U), cosφ _{fix} , Q _{fix} , cosφ(P) <u>Limitations</u> 0.95 _{underexcited} to 0.95 _{overexcited}	47.5 Hz ↔ 51.5 Hz	$\Delta(\frac{P}{P_M}) = 40\% \text{ (50.2Hz} - f)$ 50.2Hz < f < 51.5Hz
Low Voltage (<10 kV)	0.8 U _N ↔ 1.1 U _N	✗	<u>Method</u> cosφ _{fix} , cosφ(P) <u>Limitations</u> 0.90 _{un} to 0.90 _{ov} $\sum s_{E_{MAX}} > 13.8kVA$ 0.95 _{un} to 0.95 _{ov} $\sum s_{E_{MAX}} \leq 13.8kVA$	47.5 Hz ↔ 51.5 Hz	$\Delta(\frac{P}{P_M}) = 40\% \text{ (50.2Hz} - f)$ 50.2Hz < f < 51.5Hz

OUTLINE

- 
1. INTRODUCTION
 2. MODEL
 3. CONTROL ASPECTS
 4. CONCLUSIONS & RECOMMENDATIONS

The model




- PV system is modeled by a static generator
- Nominal capacity: 0.5 MVA
- Designed PF: 0.95
- Active power operational limits: 475 kW


Steady state operation

- Active power supply: 450 kW
(defined by the configuration of the PV array)
- Reactive power supply: 0 kVar ($\cos\phi = 1$)

The control frame




The DC side




- The array outputs are based on the ideal cell model. Temperature corrections and module interconnection
- The voltage input of the inverter is calculated in the DC terminal

The AC side





OUTLINE



Active Power Control

Test:

- Create an over-frequency event at 51 Hz



Results:


- The active power is being reduced from 0.9 p.u. to 0.61 p.u., meaning a reduction of ≈ 31.7%
- The controller is effective with a dynamic response around 50 ms

Dynamic voltage support-FRT

Test:

- Create four different tests

Test	Voltage dip [%]	Duration of fault [ms]
1	30	150
2	45	550
3	60	1000
4	70	1500




guidelines

duration of fault [ms]

150
550
1000
1500

Aggregate table of Results

Voltage dip [%]	Duration of fault [ms]
100	150
80	550
50	1000
20	1500



Injected reactive current [kA]


0,681
0,542
0,342
0,119

Example of 100% voltage dip


- The reactive current injection:

$$i_q = K |du_{ac}|$$

where, $du_{ac} = u_{ac}$ before fault $- u_{ac}$ during the fault and $K=1$




Static voltage support/Controller



Static voltage support/Results (1)

Test:

- Create a reduction in the active power injection (examine Q_{fix} $\cos\phi_{fix}$, $\cos\phi$ (P) modes)





Results:

- Q supply based on a given set-point
- Q supply by keeping the power factor constant in active power changes
- Q supply based on a characteristic

Static voltage support/Results (2)

Test:


- Create an overvoltage within normal limits



Results:

- The inverter consumes reactive power due to the overvoltage based on a droop
- The controller reaches and operates in the reactive power limitations

OUTLINE



Conclusions - Recommendations

Conclusions:

The model is capable of:

- Active power control requirement
- LVRT requirement-Dynamic voltage support
- Static voltage support (four-mode controller)

Recommendations:

Further studies:

- Testing the PV model and control scheme under different Grid Codes (UK, Denmark, Spain, France etc)
- Enhance the model and perform more detail and sensitive protection studies (e.g. over/under - voltage studies, over/under - frequency studies)

Thank you for your attention

Mange tak ...

Vielen Dank ...

Ευχαριστώ ...

